

KOŁBIEL - ilości powietrza wentylacyjnego

ozn.	pom	F	H	NAWIEW			WYWIEW			Qn	Qw	UWAGI
				Vn	Nn	zespół	Vw	Nw	zespół			
-	-	m ²	m	m ³ /h	w/h	-	m ³ /h	w/h	-	-		
0.1	WIATROŁAP	3,7	3,0		0,0			0,0		0	0	
0.2	KORYTARZ	75,3	3,0		0,0		50	0,2		0	50	
0.3	POKÓJ DYREKTORA	13,3	3,0	50	1,3			0,0		50	0	
0.4	POKÓJ ADMISTR.	11,9	3,0	50	1,4			0,0		50	0	
0.5	MAGAZYN PORZĄD.	4,8	3,0		0,0		30	2,1		0	30	wyrzut
0.15	KL. SCHODOWA	6,0	3,0		0,0		30	1,7		0	30	
0.32	KORYTARZ	16,0	3,0	100	2,1			0,0		100	0	
0.37	WIATROŁAP	8,4	3,0		0,0		40	1,6		0	40	
1.1	KL. SCHODOWA	24,2	4,0		0,0		0	0,0		0	0	
1.2	WC DZIECI	11,5	4,0		0,0		150	3,3		0	150	
1.3	WC MĘSKI	6,8	4,0		0,0		80	2,9		0	80	
1.4	KUCHENKA	8,2	4,0		0,0		70	2,1		0	70	
1.5	POKÓJ SOCJALNY	14,0	4,0	50	0,9			0,0		50	0	
1.6	KORYTARZ	33,9	4,0	50	0,4			0,0		50	0	
1.7	SALA WIELOFUNKC.	82,0	4,0	500	1,5		300	0,9		500	300	
1.8	MAGAZYN	16,4	4,0		0,0		50	0,8		0	50	wyrzut
0.16	SZATNIA PERSONELU	13,7	3,0	200	4,9		200	4,9		200	200	
0.17	KORYTARZ	43,8	3,0	210	1,6			0,0		210	0	

0.22	WIATROLAP	3,2	3,0		0,0			0,0		0	0	
0.6	POM. NA LEŻANKI	5,3	3,0		0,0		60	3,8		0	60	
0.12	POM. NA LEŻANKI	5,8	3,0		0,0		60	3,4		0	60	
0.13	POM. NA LEŻANKI	5,8	3,0		0,0		60	3,4		0	60	
0.23	POM. NA LEŻANKI	4,0	3,0		0,0		60	5,0		0	60	
0.28	POM. NA LEŻANKI	4,0	3,0		0,0		60	5,0		0	60	
0.30	POM. NA LEŻANKI	4,0	3,0		0,0		60	5,0		0	60	
0.53	SZATNIA	71,1	3,0	450	2,1		450	2,1		450	450	
0.18	POM. PORZĄDK.	3,5	3,0		0,0		30	2,8		0	30	
				860			1040					
0.7	SALA DZIECI	57,6	3,0	360	2,1			0,0		360	0	
0.10	ŁAZIENKA	11,9	3,0		0,0		300	8,4		0	300	
0.9	ŁAZIENKA	11,9	3,0		0,0		300	8,4		0	300	
0.11	SALA DZIECI	57,6	3,0	360	2,1			0,0		360	0	
0.14	SALA DZIECI	57,6	3,0	360	2,1			0,0		360	0	
0.20	ŁAZIENKA	12,4	3,0		0,0		300	8,1		0	300	
0.24	SALA DZIECI	57,5	3,0	360	2,1			0,0		360	0	
0.26	ŁAZIENKA	11,5	3,0		0,0		300	8,7		0	300	
0.25	ŁAZIENKA	11,5	3,0		0,0		300	8,7		0	300	
0.27	SALA DZIECI	57,5	3,0	360	2,1			0,0		360	0	
0.29	ŁAZIENKA	11,5	3,0		0,0		300	8,7		0	300	
0.31	SALA DZIECI	64,6	3,0	360	1,9			0,0		360	0	

0.19	WC PERSONELU	3,8	3,0		0,0		80	7,1		0	80	
0.21	ŁAZIENKA	7,1	3,0		0,0		140	6,5		0	140	
0.8	WC NPS	6,3	3,0		0,0		140	7,5		0	140	
				2160			2160					
0.33	POM. NA ODPADKI	2,4	3,0		0,0			0,0		0	0	osobny wyciąg
0.35	KOTŁOWNIA	10,0	3,0		0,0			0,0		0	0	grawitacja
0.34	POKÓJ KIEROWNIKA	8,0	3,0	100	4,2			0,0		100	0	wywiew na korytarz
0.36	WIATROŁAP	3,2	3,0		0,0			0,0		0	0	
0.38	ŁAZIENKA	4,7	3,0		0,0		100	7,2		0	100	
0.39	POKÓJ SOCJALNY	7,0	3,0	100	4,8			0,0		100	0	
0.40	PRZECHOW. JAJ	6,8	3,0		0,0		120	5,9		0	120	nawiew z korytarza
0.41	MAGAZYN WARZYW	3,4	3,0		0,0		80	7,8		0	80	nawiew z korytarza
0.42	PRZEDSIONEK	1,4	3,0		0,0			0,0		0	0	
0.43	PRZYG. WARZYW	7,4	3,0	150	6,8		150	6,8		150	150	
0.44	POM. URZ. CHŁODN.	11,2	3,0	1200	35,7		1200	35,7		1200	1200	
0.45	MAG. PROD. SUCHYCH	6,4	3,0		0,0		100	5,2		0	100	nawiew z korytarza
0.46	MYCIE WÓZKÓW	8,4	3,0	120	4,8		120	4,8		120	120	
0.47	ZMYWALNIA	11,8	3,0	350	9,9		350	9,9		350	350	
0.48	PRZYG. WARZYW	7,0	3,0	120	5,7		120	5,7		120	120	

0.49	PRZYG. MIĘSA I DROB.	7,3	3,0	180	8,3		180	8,3		180	180	
0.50	KORYTARZ	18,0	3,0	200	3,7			0,0		200	0	
0.51	EKSPEDYCJA	5,6	3,0	100	6,0		100	6,0		100	100	
0.52	KUCHNIA	45,8	3,0	1890	13,8		2100	15,3		1890	2100	
0.52	KUCHNIA OKAPY	1,9	2,0		0,0		3000	789,5		0	3000	osobny wyciąg x 3